



SOLAR ARRAY



1925 Ridgeway St. | Hammond, WI 54015
715-796-7000 | www.scecnet.net
This institution is an equal opportunity provider.




INVERTERS




AUTOMATIC DISCONNECT

ST CROIX ELECTRIC COOPERATIVE PRODUCTION METER 120/240V, 200A WITH BYPASS 1-PHASE, 3-WIRE




UTILITY AC DISCONNECT VISIBLE-OPEN TYPE, LOCKABLE, READILY ACCESSIBLE



ST CROIX ELECTRIC COOPERATIVE UTILITY METER 120/240V, 1-PHASE, 3-WIRE

LINETAP INSIDE NEW 320A METER SOCKET VIA UL-LISTED DOUBLE LUGS ON LINE SIDE OF METER



TO UTILITY

1. DESIGN MEETS NEC CODE AND SHALL BE INSTALLED IN ACCORDANCE WITH NEC 690 AND POSTED WITH APPLICABLE WARNINGS, SIGNAGE, AND PLAQUES PER NEC 705-10, 690-17, & 690-64 (b) (5)

ELECTRICAL LINE DIAGRAM

*DISTANCES NOT TO SCALE